SCHEMATIC FOR INTRINSICALLY SAFE RELAY OUT

Continuity wiring on "Plug" terminals. Produces an alarm if circular connector is disconnected.

Continuity jumper located in male circular plug.

Intrinsically Safe barrier (required)

J1 Relay output.

LS1 wires to float switch or other "Simple Device". (N.C.)

LS2 is for an optional second float switch or other "Simple Device" (N.C.) Different alarm pattern from LS1.

Sep 4, 2019