

CERTIFICATE OF COMPLIANCE

Certificate Number 20130723- E12629
Report Reference E12629-20050120
Issue Date 2013-JULY-23

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484


This is to certify that representative samples of AUDIBLE-SIGNAL APPLIANCES FOR USE IN HAZARDOUS LOCATIONS
See addendum page


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203, Standard for Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous Locations.
ANSI/ISA 12.12.01, Standard for Non-incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.
C22.2 No. 0, C22.2 No. 0.4, C22.2 No. 30, Standard for Explosion-Proof Enclosures for Use in Class I Hazardous Locations.
C22.2 No. 157, Standard for Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations
C22.2 No. 213 Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations .
ULC Standard ULC-S525-07 Standard for Audible Signal Devices For Fire Alarm Systems Including Accessories

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130723- E12629
Report Reference E12629-20050120
Issue Date 2013-JULY-23


Look for the UL Listing Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL - 1- Audible Signal Appliances For Fire Alarm Service For Use In Hazardous Locations, Models 304X, 314X, ASHX, and ASUX when used with Federal Signal's Listed (UGKZ, UGKZ7) plug-in module, Models UTC or UTM. Hazardous Locations, Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Indoor/Outdoor Use; Operating Ambient -40°C to +66°C.

USL-2- Fire Protective Signaling Speaker For Fire Alarm Service For Use In Hazardous Locations, Models 304X, 314X, ASHX and ASUX when used with Federal Signal's Listed (UGKZ) plug-in module, Model 300CKs, AM25CK, CK25, AM70CK or CK70. Hazardous Locations, Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Indoor/Outdoor Use; Operating Ambient -40°C to +66°C.

CNL- Audible Signal Appliances For Fire Alarm Service For Use In Hazardous Locations, Models 304X-024-CN, 314X-024-CN, ASHX-024-CN and ASUX-024-CN when used with Federal Signal's Listed (UGKZC) plug-in module, Model UTM. Hazardous Locations, Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Indoor/Outdoor Use; Operating Ambient -40°C to +66°C.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

