

CERTIFICATE OF COMPLIANCE

Certificate Number 20190221-E12629
Report Reference E12629-20190220
Issue Date 2019-FEBRUARY-21

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484-3167

**This certificate confirms that
representative samples of**

AUDIBLE-SIGNAL APPLIANCES FOR USE IN
HAZARDOUS LOCATIONS

See Addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 121201 : Nonincendive Electrical Equipment for Use in
Class I and II, Division 2 and Class III, Divisions 1 and 2
Hazardous (Classified) Locations.

UL 464A : Audible Signal Appliances for General Signaling
Use.

CAN/CSA- C22.2 No. 213-17 : Nonincendive electrical
equipment for use in Class I and II, Division 2 and Class III,
Divisions 1 and 2 hazardous (classified) locations

CSA C22.2 No. 205-17 : Signal Equipment

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190221-E12629
Report Reference E12629-20190220
Issue Date 2019-FEBRUARY-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Audible Signal Appliances, General Signaling, Model SST3GCX-MV for use in Hazardous Locations, Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Outdoor Use;


Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

