

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190322-E162478  
**Report Reference** E162478-19940516  
**Issue Date** 2019-MARCH-22

**Issued to:** FEDERAL SIGNAL CORP SIGNAL DIV  
2645 FEDERAL SIGNAL DR  
UNIVERSITY PARK, IL 60484-3167 USA

**This certificate confirms that  
representative samples of**

FIRE ALARM DEVICES FOR USE IN HAZARDOUS  
LOCATIONS

Class I Groups C and D; Class II Groups E, F and G, fire  
alarm devices: MPEX

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 1203-Explosion-Proof and Dust-Ignition-Proof Electrical  
Equipment for Use in Hazardous (Classified) Locations;  
CAN/CSA C22.2 No. 25-1966-Enclosures for Use in Class  
II Groups E, F, and G Hazardous Locations;  
CAN/CSA C22.2 No. 30-M1986-Explosion-Proof  
Enclosures for Use in Class I Hazardous Locations

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

