

XP CLIMATE CONTROL LLC. CERTIFICATE OF CONFORMANCE

National Electric Code

Explosion Proof HVAC Equipment

The certificate certifies that to the best of our knowledge the equipment manufactured

Model Number: EP-MS36HP-1-2-B-(IE)-216-1Z

Serial Number:

conforms to the requirements the
United States of America National Electrical Code
for the following locations:


Interior and Exterior Section: Class 1 Division 2 Groups B, C and D.

The equipment shall be installed and operated only in the hazardous locations identified in this certificate and in accordance with applicable code requirements.

Conformance I.D. CC-COC-113-Standard, NEC Article 500,

IEC Zone II Groups IIA and IIB-T3

Certification Date: 5/27/2026



Will Knight