

Certificate of Compliance

Certificate: 1929803 (LR 58491-3)

Master Contract: 174186

Project: 2322615

Date Issued: July 19, 2010

Issued to: Tomar Electronics Incorporated

2100 W. Obispo Ave.
Gilbert, AZ 85233-3401
USA

Attention: Frank Szkutak

The products listed below are eligible to bear the CSA Mark shown



Joe da Silva

Issued by: Joe da Silva, C.E.T.

PRODUCTS

CLASS 3428 03 - FIXTURES AND FITTINGS - For Hazardous Locations

Class I, Div 2, Groups A, B, C and D; Class II, Div 2, Groups F and G, Class III Div 2; Encl Type 3.

Strobe lights, Model 4375-120/240, rated 120V through 240V ac, 50/60 Hz, 11W at 120V ac and 40W at 240V ac; Model 4375-1274, rated 12 through 74V dc, 15W at 12V dc and 50W at 74V dc. Temp Code T2A.

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-M91 (R2001) - General Requirements - Canadian Electrical Code, Part II

CSA Std C22.2 No. 137-M1981 - Electric Luminaires for Use in Hazardous Locations

MARKINGS

- Submitter's name or trademark
- Model No designation
- Electrical ratings (Eg - Volts, Watts, and Frequency)



Certificate: 1929803 (LR 58491-3)

Master Contract: 174186

Project: 2322615

Date Issued: July 19, 2010

-
- Hazardous location designation
 - Type 3 designation
 - Temperature code T2A (280C)
 - Bilingual Caution: "CAUTION: KEEP ASSEMBLY CLOSED TIGHT WHILE CIRCUITS ARE ALIVE, DANGER: HIGH VOLTAGE TURN POWER OFF AND WAIT FIVE MINUTES BEFORE SERVICING" and ATTENTION: GARDER L'ASSEMBLAGE BIEN FERME LORSQUE LE CIRCUITS SONT SOUS TENSION" or equivalent
 - CSA Monogram.