



INSTRUCTIONS FOR SAFE USE

EXISTM LITHIUM 7.4V
INTRINSICALLY SAFE
BATTERY PACK





CONTENTS

Safety Information	3
Overview	3
Safety Information	3
Faults and Damage	3
Safety Regulations	4
Special Conditions for Safe Use	4
Installation and Setting to Work	4
Transportation and Storage	4
Cleaning and Maintenance	4
Safety Precautions	4
Aggressive Substances and Environments	4
Exposure to External Stresses	4
Labelling	5
Certification	6
EC Declaration of Conformity	6
EU Type Examination Certificate	7-10
IECEx Certificate of Conformity	11-15

SAFETY INFORMATION

Read and understand all warnings and cautions before using this product.

Overview

The CorDEX Instruments EXIS Battery Pack is an intrinsically safe battery pack. The EXIS Battery Pack is designed to be used in hand-held devices as an Ex Component. The battery pack includes the safety critical components that limit the output parameters.

A protector is provided for mechanical protection and to maintain IP54 rating when the battery pack is not assembled in a host device.

Safety Information

This instruction manual contains information and warnings that must be observed for safe operation under the conditions described.

Faults and Damage

If there are any grounds to believe the unit is no longer safe to use, it must be taken out of service and measures taken to prevent its further unintentional use.

The safety of the device may be impaired if for example:

- External damage to the unit is visible.
- The device has not been stored correctly.
- The unit has suffered transport damage.

Safety Regulations

When using the EXIS Intrinsically Safe Battery Pack the appropriate regulations must be observed to avoid incorrect operation of the device.

ATTENTION! ENSURE THAT THE BATTERY PACK IS PROPERLY ATTACHED WHEN IN USE.

Special Conditions of Safe Use

- The EXIS Battery Pack cannot be used in hazardous areas except with a certified host device.
- In hazardous areas the protector should be in place when the battery pack is not attached to a host device.
- Only CorDEX approved accessories are permitted to be used in the EXIS battery pack.
- Only LG ICR18650D1 Lithium cells are approved to be used within this Ex Component as follows:

Operating temperature: -10°C to 40°C Charging temperature: 0°C to 45°C



SAFETY INFORMATION

Exposure to External Stresses

protection may be required.

The EXIS Battery Pack is not intended for

beyond its design capability. Additional

use with vibration, impact and heat stresses

Installation and Setting to Work

For the installation, maintenance and cleaning of the units observe the applicable regulations and provisions concerned with explosion protection (EN 60079-0, EN 60079-14).

Transportation and Storage

Transport and store without imposing excessive mechanical stresses. Store in a cool dry place.

Cleaning and Maintenance

The EXIS Battery Pack and accessories require no maintenance. For safety critical maintenance, please refer to EN60079-17.

Safety Precautions

For the installation, maintenance and cleaning of the units observe the applicable regulations and provisions concerned with explosion protection (EN 60079-0, EN 60079-14).

Aggressive Substances and Environments

Consideration shall be given to the risk of degradation of the camera due to aggressive substances. Additional protection may be required.

LABELLING

CorDEX Instruments Ltd, 1 Owens Rd, TS66HE, UK EXIS - battery pack



II 2G

ATEX: - ExVeritas 18ATEX0349U IECEx: - IECEx EXV 18.0012U Ex ib IIC Tamb -10°C to +40°C



Year of construction - XXXX

XXXX* Serial Number XXXX-XX-XXXXXX

*Refers to CorDEX current QAN Certificate which is available upon request WARNING: NON REPLACEABLE COMPONENTS INSIDE SEE USER MANUAL FOR MORE INFORMATION. DO NOT CHARGE IN HAZARDOUS AREA.

Manufacturer Contact Information

Email: sales@cord-ex.com Phone: +44 (0)1642 454373 Fax: +44 (0)1642 424737

CorDEX Instruments Limited
Unit 1 Owens Road
Skippers Lane Industrial Estate
Middlesbrough
TS6 6HE


RUGGED AUTHORITY



EC DECLARATION OF CONFORMITY

CorDEX CorDEX Instruments Ltd. 1 Owens Road Skippers Lane Industrial Estate Middlesbrough TS6 6HE Declaration No. SO17 Rev. A **EC Declaration of Conformity** In accordance with EEC ATEX Directive 2014/34/EU CorDEX Instruments Ltd Hereby declare that the products described below; Product: **EXIS Battery** Model: EXIS 740 Battery are in conformity with the essential health and safety requirements of Council Directive 2014/34/EU relating to equipment intended for use in potentially explosive atmospheres (ATEX Directive) Ex II 2G Ex ib IIC (Ta = -10°C to +40°C) equipment, by the application of the following Standards:-BS EN 60079-0:2012 + Explosive atmospheres - Part 0: Equipment - General requirements A11:2013 BS EN 60079-11:2012 Explosive atmospheres. Equipment protection by intrinsic safety "i" and are subject to the procedure set out in Annex VII of Directive 2014/34/EU and these procedures are in conformity with the requirements of EN 80079-34 under the supervision of Notified Body Number 0518, SIRA Certification Ltd. Unit 6, Hawarden Industrial Park, Hawarden, Deeside, CH5 3US. It is ensured through internal measures that the products conform at all times to the requirements of EU Directive 2011/65/EU on the restriction of certain hazardous substances in electrical and electronic equipment (ROHS Directive) and other current EEC Directives and relevant standards Signature: Authorised Person Managing Director on behalf of CorDEX Instruments Ltd 18/05/2018 Date: RUGGED AUTHORITY www.cord-ex.com Form Revision Date 28/04/2016

EU TYPE EXAMINATION CERTIFICATE







Schedule

Description of Equipment or Protective System

The intrinsically safe battery pack EXIS is designed to be used in hand-held devices as an Ex Component. It is comprised of two LG ICR18650D1 Lithium cells connected in series and a board that includes the safety critical components that limit the output parameters. The cells and the board are encapsulated and housed in a suitable enclosure, this enclosure includes an external connector that is covered by a cap to provide mechanical protection and IP54 rating when not assembled in a host device.

Electrical Output Parameters

Host equipment provided with infallible galvanic insulation:

Terminals combination	Uo	lo	P ₀	Uconstant	Prontert	Ci and Li
PWR_EXIS_DSP vs PWR_0V	8.4 V	750 mA	1.6 W	7.6 V	1.2 W	Negligible
PWR_EXIS_LCD vs PWR_0V	8.4 V	750 mA	1.6 W	7.6 V	1,2 W	Negligible
PWR_EXIS_SENSOR vs PWR_0V	8.4 V	750 mA	1.6 W	7.6 V	1.2 W	Negligible
PWR_EXIS_VRAIL1 vs PWR_0V	8.4 V	657 mA	1.4 W	7.6 V	920 mW	Negligible
PWR_EXIS_VRAIL2 vs PWR_0V	8.4 V	657 mA	1.4 W	7.6 V	920 mW	Negligible
EXIS_CONTROL vs PWR_0V	8.4 V	18 mA	40 mW	7.6 V	31 mW	Negligible

- Each power circuit has the same PWR_OV potential, because all the lines are connected to the negative pole of the cells series association. However, each circuit has a PWR_OV line infallible segregated of the others, which assure that the combination of the currents at only one PWR_OV line is not possible to the output.

 Constant Power and Voltage shall be considered for thermal evaluations.

When the host equipment is provided without galvanic insulation and the different IS circuits can be combined, the following parameters apply:

U_o = 8.4 V Constant parameters: U = 7.6 V @ I = 425 mA @ P = 1.2 W PWR_EXIS_DSP: In = 3.6 A PWR_EXIS_LCD: U = 7.6 V @ I = 425 mA @ P = 1.2 W P+ = 7.5 W PWR_EXIS_SENSOR: U = 7.6 V @ I = 425 mA @ P = 1.2 W PWR_EXIS_VRAIL1: U = 7.6 V @ I = 425 mA @ P = 920 mW PWR_EXIS_VRAIL2: U = 7.6 V @ I = 425 mA @ P = 920 mW EXIS_CONTROL: U = 7.6 V @ I = 16 mA @ P = 31 mW PWR_0V under fault: 1= 2.14 A

Charger rating shall be according to the following:

ExVeritas 18 ATEX 0349U

This certificate may only be reproduced in its entirety and without any change, schedule included.

For help or assistance relating to this certificate, contact <u>info@excertlas.com</u>.

ExVertas, Units 16-15, Abenbury Way, Wrexham Industrial Estate, Wardum, United Kingdom LL13 9UZ.

ExVertas® is a registered trademark, unauthorised use will lead to prosecution.

FO-CB-38 V1 Page 2 of 4



Schedule

Descriptive Documents

14.1 Associated Report and Certificate History:

Report Number	Cert Issue Date	Issue	Comment	
R1525/A/1	06/06/2018	0	Initial issue of the Prime Certificate	

14.2 Compliance Drawings:

- 1	ls	8	u	e	0	

Title:	Drawing No.:	Rev. Level:	Date:
EXIS BatteryPack System	CDX1000-200	1.3d	2015/05/21
CorDEX EXIS-740 BatteryPack System Schematic BOM	CDX1000-201	1.3d	2015/05/21
Instructions for Safe Use Intrinsically Safe Battery Pack	EE740SOM	С	2018/03/21
EXIS BatteryPack schematic	CDX1000-220	1.3	2015/04/30
EXIS BatteryPack BOM (Certification)	GDX1000-222	1.3	2015/05/21
EXIS BatteryPack PCB fabrication drawing	CDX1000-223	1.3	2015/05/01
EXIS BatteryPack PCB assembly drawing	GDX1000-224	1.3	2015/05/01
EXIS BatteryPack RS274 (gerbers)	CDX1000_EXISBatteryPack	1.3	2015/05/01
EXIS PackConn schematic	CDX1000-240	1.4	2016/03/07
EXIS PackConn BOM (Certification)	CDX1000-242	1.4	2016/03/11
EXIS PackConn PCB fabrication drawing	CDX1000-243	1,4	2016/03/10
EXIS PackConn PCB assembly drawing	CDX1000-244	1.4	2016/03/10
EXIS PackConn RS274 (gerbers)	CDX1000_EXISPackConn	1.4	2016/03/07
EXIS BatteryPack General Assembly	CDX1000-019	D	2018/04/06
EXIS BatteryPack encapsulation	CDX1000-025	D	2015/07/25
EXIS BatteryPack clip General Assembly	CDX1000-030	D	2018/04/06
EXIS BatteryPack rating plate	CDX1000-441	E	2018/04/06

Conditions of Certification

ExVeritas 18 ATEX 0349U

This certificate may only be reproduced in its entirely and without any change, schedule included.

For help or assistance relating to this certificate, contact incofferencias com.

ExVeritas, Units 16-18, Abenbury Way, Wrosham Industrial Estate, Westham, United Kingdom LL13 9UZ.

EXVeritas® is a registered trademark, unauthorised use will lead by prosecutions.


Page 3 of 4

FO-CB-38 V1



ExVeritas° Schedule 15.1 Schedule of Limitations: . This an Ex Component and cannot be used in explosive atmospheres if not certified with a host device. Only LG ICR18650D1 Lithium cells are approved to be used on this Ex Component. . The capacitance and inductance of the host device shall be assessed in accordance with the maximum parameters provided in the specifications. Conditions for Use (Routine Tests) N/A Essential Health and Safety Requirements Essential Health and Safety Requirements are addressed by the standards listed in section 9 and where required the report listed in section 14.1 The manufacturer shall inform the Notified Body of any modifications to the design of the product ExVeritas 18 ATEX 0349U This certificate may only be reproduced in its entirety and without any change, schedule included. For help or assistance relating to this certificate, contact info@enventas.com ExVeritas, Units 16-18, Abenbury Way, Wrexham Industrial Estate, Wrexham. Units 16-18, Denbury Way, Wrexham Industrial Estate, Wrexham. Units 16-18, Denbury Way, Wrexham Industrial Estate, Wrexham. United Kingdom LL13 9UZ. ExVeritas 8 is a registered trademark, unauthorised use will lead to projecution. FO-CB-38 V1 Page 4 of 4

IECEX CERTIFICATE OF CONFORMITY









RUGGED AUTHORITY

Document Reference EXISSOM Re



Annex to: IECEx EXV 18.0012U Issue 0



Description Continued: Electrical Output Parameters

Host equipment provided with infallible galvanic insulation:

Terminals combination	Lla	14	Pe	Unner	Pointer	C and L
PWR_EXIS_DSP vs PWR_6V	84 V	750 mA	1.6 W	7.6 V	1.2 W	Negligible
PWR_EXIS_LCO vs PWR_0V	8.4 V	750 mA	1.6 W	7.6 V	1.2 W	Negligible
PWR_EXIS_SENSOR vs PWR_0V	84 V	750 mA	1.6 W	7.6 V	1.2 W	Negligible
PWR_EXIS_VRAIL1 VE PWR_OV	84 V	667 mA	1.4 W	7.6 V	920 mW	Negligible
PWR_EXIS_VRAIL2 vs PWR_0V	8.4 V	667.mA	1.4 W	7.6 V	920 mW	Negligible
EXIS_CONTROL vs PWR_0V	8.4 V	18 mA	40 mW	7.6 V	31 mW	Negligible

Each power circuit has the same PWR_0V potential, because all the lines are connected to the negative pole of the cells series association. However, each circuit has a PWR_0V line infallate aspregated of the others, which assure that the combination of the currents at only one PWR_0V line is not possible to the output.
 Constant Power and Vollage shall be considered for thermal evaluations.

When the host equipment is provided without galvanic insulation and the different IS circuits can be combined, the following parameters apply:

Ua = 8.4 V I₄ = 3.6 A Pa = 7.5 W Constant parameters:

PWR_EXIS_DSP: U = 7.6 V @ I = 425 mA @ P = 1.2 W
PWR_EXIS_LCD: U = 7.6 V @ I = 425 mA @ P = 1.2 W
PWR_EXIS_SENSOR: U = 7.6 V @ I = 425 mA @ P = 1.2 W

PWR_EXIS_VRAIL1: U = 7.6 V @ 1 = 425 mA @ P = 920 mW PWR_EXIS_VRAIL2: U = 7.6 V @ 1 = 425 mA @ P = 920 mW

EXIS_CONTROL: U = 7.6 V @ I = 16 mA @ P = 31 mW
PWR_0V under fault: I = 2.14 A

Charger rating shall be according to the following: Um = 8.4 V

Routine Tests:

Schedule of Limitations:

- 1. This is an Ex Component and cannot be used in an explosive atmospheres if not certified
- 2. Only LG ICR18650D1 Lithium cells are approved to be used in this Ex Component.
- 3. The capacitance and inductance of the host device shall be assessed in accordance with the maximum parameters provided in the specifications.

Page 1 of 2

ExVeritas, Units 16-18, Abenbury Wsy, Wrechsm Industrial Estate, Whexham, United Kingdom LL13 9UZ.

FO-CB-34 V1

Annex to: IECEx EXV 18.0012U Issue 0



Title:	Drawing No.:	Rev	Date:
EXIS BatteryPack System	CDX1000-200	1.3d	2015/05/21
CorDEX EXIS-740 BatteryPack System Schematic BOM	CDX1000-201	1.3d	2015/05/21
Instructions for Safe Use Intrinsically Safe Battery Pack	EE740SOM	С	2018/03/21
EXIS BatteryPack schematic	CDX1000-220	1.3	2015/04/30
EXIS BatteryPack BOM (Certification)	CDX1000-222	1.3	2015/05/21
EXIS BatteryPack PCB fabrication drawing	CDX1000-223	1.3	2015/05/01
EXIS BatteryPack PCB assembly drawing	CDX1000-224	1.3	2015/05/01
EXIS BatteryPack RS274 (gerbers)	CDX1000_EXISBatteryPack	1.3	2015/05/01
EXIS PackConn schematic	CDX1000-240	1.4	2016/03/07
EXIS PackConn BOM (Certification)	CDX1000-242	1.4	2016/03/11
EXIS PackConn PCB fabrication drawing	CDX1000-243	1.4	2016/03/10
EXIS PackConn PCB assembly drawing	CDX1000-244	1.4	2016/03/10
EXIS PackConn RS274 (gerbers)	CDX1000_EXISPackConn	1.4	2018/03/07
EXIS BatteryPack General Assembly	CDX1000-019	D	2018/04/06
EXIS BatteryPack encapsulation	CDX1000-025	D	2015/07/25
EXIS BatteryPack clip General Assembly	CDX1000-030	D /	2018/04/08
EXIS BatteryPack rating plate	CDX1000-441	E	2018/04/08

Page 2 of 2

ExVeritas, Units 16-18, Abendury Way, Wreytham Industrial Estate, Wreytham, United Kingdom LL13 9UZ.

FO-CB-34 V1

Copyright © 2018, CorDEX Instruments Limited.