



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx IBE 19.0023X

Issue No: 0

Certificate history:

Issue No. 0 (2019-09-11)

Status: **Current**

Page 1 of 6

Date of Issue: **2019-09-11**

Applicant: **Extronics Ltd**
1 Dalton Way,
Midpoint 18
Middlewich
CHESHIRE
CW10 0HU
United Kingdom

Equipment: **hand scanner and accessories**

Optional accessory:

Type of Protection: **Intrinsic safety "i", increased safety "e", encapsulation "m" or protection by enclosure "t"**

Marking:

Hand scanner with cable:

iSCAN102, iSCAN1092D

Ex ic IIC T4 Gc

Ex ic IIIC T135 °C Dc

$-20\text{ °C} \leq T_{\text{amb}} \leq +50\text{ °C}$

iSCAN1022D

Ex ic IIB T4 Gc

Ex ic IIIC T135 °C Dc

$-20\text{ °C} \leq T_{\text{amb}} \leq +50\text{ °C}$

Hand scanner, battery operated:

iSCAN212, iSCAN2022D, iSCAN2122D

Ex ic IIB T4 Gc

Ex ic IIIC T135 °C Dc

$-20\text{ °C} \leq T_{\text{amb}} \leq +50\text{ °C}$

Base station:

iSCAN212EXB, iSCAN202EXB2D, iSCAN212EXB2D

Ex ic IIC T4 Gc

Ex ic IIIC T135 °C Dc

$-20\text{ °C} \leq T_{\text{amb}} \leq +50\text{ °C}$



IECEx Certificate of Conformity

Certificate No: IECEx IBE 19.0023X

Issue No: 0

Date of Issue: 2019-09-11

Page 2 of 6

Supply module:

SDVM-SD160II^{EX}

[Ex ic Gc] IIC

[Ex ic Dc] IIIC

At type SD.321.xxxx.1x with $-20\text{ °C} \leq T_{\text{amb}} \leq +60\text{ °C}$

At type SD.321.xxxx.2x (High Power) with $-20\text{ °C} \leq T_{\text{amb}} \leq +50\text{ °C}$

Supply module:

SDVE-SD160II^{EX}

Ex ec [ic] IIC T4 Gc

(with SDVM-SD160II^{EX})

Ex tc [ic] IIIC T135°C Dc

at type SD.251.xxxx.1x with $-20\text{ °C} \leq T_a \leq +60\text{ °C}$

at type SD.251.xxxx.2x (High Power) with $-20\text{ °C} \leq T_a \leq +50\text{ °C}$

Supply cable:

iSCANPSCABU and iSCANPSCABR

Ex mc [ic] IIC T4 Gc

Ex mc [ic] IIIC T135°C Dc

$-20\text{ °C} \leq T_{\text{amb}} \leq +70\text{ °C}$

Approved for issue on behalf of the IECEx

Certification Body:

Dipl.-Ing. Alexander Henker

Position:

Head of Certification Body

Signature:

(for printed version)

Date:

2019-09-11

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](#).

Certificate issued by:



IECEX Certificate of Conformity

Certificate No: IECEx IBE 19.0023X

Issue No: 0

Date of Issue: 2019-09-11

Page 3 of 6

IBExU Institut für Sicherheitstechnik GmbH
Certification Body
Fuchsmühlenweg 7
09599 Freiberg
Germany





IECEX Certificate of Conformity

Certificate No: IECEX IBE 19.0023X

Issue No: 0

Date of Issue: 2019-09-11

Page 4 of 6

Manufacturer: **Extronics Ltd**
1 Dalton Way,
Midpoint 18
Middlewich
CHESHIRE
CW10 0HU
United Kingdom

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2017 Edition:7.0	Explosive atmospheres - Part 0: Equipment - General requirements
IEC 60079-11 : 2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-18 : 2017 Edition:4.1	Explosive atmospheres - Part 18: Protection by encapsulation "m"
IEC 60079-31 : 2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
IEC 60079-7 : 2017 Edition:5.1	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[DE/IBE/ExTR19.0022/00](#)

Quality Assessment Report:

[GB/SIR/QAR08.0025/09](#)



IECEx Certificate of Conformity

Certificate No: IECEx IBE 19.0023X

Issue No: 0

Date of Issue: 2019-09-11

Page 5 of 6

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The hand scanners are hand-held, intrinsically safe devices and are used to read barcodes in hazardous areas of EPL Gc and Dc (Zone 2 or Zone 22).

The types iSCAN102, iSCAN1092D and iSCAN1022D are provided with a cable. Power supply and data transmission are carried out via an exchangeable connecting cable.

The types iSCAN212, iSCAN2022D and iSCAN2122D are battery operated. Power is supplied by an internal battery. Data can be transmitted wirelessly via Bluetooth connection to a base station of type iSCAN212EXB, iSCAN202EXB2D and iSCAN212EXB2D, which is also designed for operation in hazardous areas of EPL Gc and Dc.

The integrated rechargeable battery is charged after the hand scanner has been placed on the charging charger of the base station. The battery can also be charged outside the hazardous area with a separate charging tray (type iSCAN20XBNOBT2D or iSCAN21XBNOBT, iSCAN211BNOBT2D, iSCAN212BNOBT2D) or using a base station (type iSCAN20XB2D or iSCAN21XB, iSCAN211B2D, iSCAN212B2D)) with power supply unit (type iSCAN2XXBLP) outside the Ex area. Furthermore, the Bluetooth handheld scanners can also be charged with a Zone 1 Bluetooth base station (type iSCAN201EXB2D, iSCAN211EXB, iSCAN211EXB2D) in Zone 2/22.

The wired hand-held scanner and the wired base station are connected to a SDVM-SD160Ilex power supply module via a connection cable. Two different variants of the supply module differ in output power (Low Power / High Power) and thus also in the permissible ambient temperature range.

The SDVM-SD160Ilex power supply module may be installed and operated in hazardous areas of EPL Gc and Dc when installed in a separately certified housing. The combination of the power supply module with a housing designed for this purpose is referred to as the SDVE-SD160Ilex power supply unit.

As an alternative to the supply module, a device designated as a supply line can be used, which is also intended for operation in potentially explosive areas of EPL Gc and Dc.

The supply cable type iSCANPSCABU and iSCANPSCABR are devices which, in addition to the data connection via USB or via the serial interfaces RS232 or RS422, provide the intrinsically safe power supply for wired hand-held scanners or for the base station with charging cradle. Only cables type iSCAN2XXCABX with a maximum length of 5 m (iSCANPSCABU) or 20 m (iSCANPSCABR) may be used for connection.

For technical data see Annex

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The ambient temperature range depends on the equipment used and is maximum -20 °C up to +70 °C.

The following conditions are valid only for the supply cable:

- Cleaning is permitted only with a damp cloth.
- The intrinsically safe parameter as well as the electrical parameter are mentioned in the instructions.
- The intrinsically safe circuit is grounded.
- The non-intrinsically safe USB connection as well as the free cable ends of the serial supply cable have to be connected outside of the hazardous area.
- The device has to be removed from the hazardous area immediately after detecting damage.



IECEX Certificate of Conformity

Certificate No: IECEx IBE 19.0023X

Issue No: 0

Date of Issue: 2019-09-11

Page 6 of 6

Annex:

[Annex_IBE19.0023X_00.pdf](#)



IECEx Certificate of Conformity - Annex



Certificate No: IECEx IBE 19.0023X

Issue No: 0

Date of Issue: 2019-09-11

Page 1 of 4

Technical data of the devices:

Hand scanner with cable	iSCAN102	iSCAN1092D	iSCAN1022D
Type	iSCAN102X	iSCAN1092D	iSCAN1022D
Type of protection:	Ex ic IIC T4 Ex ic IIIC T135°C	Ex ic IIC T4 Ex ic IIIC T135°C	Ex ic IIB T4 Ex ic IIIC T135°C
Ambient temperature range:	T_{amb} -20 °C ... +50 °C	-20 °C ... +50 °C	-20 °C ... +50 °C
Supply and data circuit:			
maximum input voltage	U_i 6.5 V	6.5 V	6.5 V
maximum internal inductance	L_i negligible	negligible	negligible
maximum internal capacitance	C_i < 150 µF	< 203 µF	< 869 µF
optical radiation	P_{opt} < 35 mW	< 35 mW	< 35 mW
light source	visible red light, $\lambda = 630$ nm		

Hand scanner BT, battery operated	iSCAN212	iSCAN2022D	iSCAN2122D
Type	iSCAN212X	iSCAN2022D	iSCAN2122D
Type of protection:	Ex ic IIB T4 Ex ic IIIC T135°C	Ex ic IIB T4 Ex ic IIIC T135°C	Ex ic IIB T4 Ex ic IIIC T135°C
Ambient temperature range:	T_{amb} -20 °C ... +50 °C	-20 °C ... +50 °C	-20 °C ... +50 °C
optical radiation	P_{opt} < 35 mW	< 35 mW	< 35 mW
light source	visible red light, $\lambda = 630$ nm		
Bluetooth	V4.0 EDR, 20 dBm (100 mW)		
Frequency	2.402 ... 2.483 GHz		
Permitted batteries	Type iSCAN201BATT (3.6 V; ≤ 2250 mAh) Type iSCAN202BATT (3.6 V; ≤ 3000 mAh) Type iSCAN2X2BATT (3.6 V; ≤ 2600 mAh)		

Base station, Bluetooth	iSCAN212EXB	iSCAN212EXB2D
Type	iSCAN212EXB	iSCAN212EXB2D
Type	iSCAN202EXB2D	
Type of protection:	Ex ic IIC T4 Ex ic IIIC T135°C	Ex ic IIC T4 Ex ic IIIC T135°C
Ambient temperature range:	T_{amb} -20 °C ... +50 °C	-20 °C ... +50 °C
Supply and data circuit:		
maximum input voltage	U_i 6.5 V	6.5 V
maximum internal inductance	L_i negligible	negligible
maximum internal capacitance	C_i < 144 µF	< 191 µF
Bluetooth	V4.0 EDR, 20 dBm (100 mW)	
Frequency	2.402 ... 2.483 GHz	



IECEx Certificate of Conformity - Annex



Certificate No: IECEx IBE 19.0023X Issue No: 0

Date of Issue: 2019-09-11 Page 2 of 4

Supply module	SDVM-SD160II^{ex}	
Type	SD.321.xxxx.1x	SD.321.xxxx.2x
Type of protection:	[Ex ic] IIC [Ex ic] IIIC	[Ex ic] IIC [Ex ic] IIIC
Ambient temperature range:	T _{amb} -20 °C ... +60 °C	-20 °C ... +50 °C
Intrinsically safe data and supply circuit (terminals X5...X10):		
maximum voltage	U _m 253 V AC	253 V AC
maximum output voltage	U _o 5.5 V DC	5.5 V DC
maximum output current	I _o 440 mA	769 mA
maximum output power	P _o 1.25 W	2.17 W
minimum internal resistance	R _i 25 Ω	14.7 Ω
characteristic	trapezoid	trapezoid
maximum external capacitance	C _o < 997 μF (L _o = 0)	< 997 μF (L _o = 0)
max. external inductance	L _o < 0.4 mH (C _o = 0)	< 0.11 mH (C _o = 0)
max. internal inductance	L _i negligible	negligible
max. internal capacitance	C _i < 2.2 μF	< 2.2 μF

Non-intrinsically safe data and supply circuit (terminals X1...X4):		
Supply circuit	12 V DC ±10 % 230 mA (xxxx.1x)	12 V DC ±10 % 360 mA (xxxx.2x)
RS232-output (Tx/D)	(Tx/D) ±12 V, 4 mA	±12 V, 4 mA
Equipotential bonding (shielding)	(PA) terminal PA	terminal PA

Supply module	SDVE-SD160II^{ex}	
Type	SD.251.xxxx.1x	SD.251.xxxx.2x
Type of protection:	Ex ec [ic] IIC T4 Ex tc [ic] IIIC T135°C	Ex ec [ic] IIC T4 Ex tc [ic] IIIC T135°C
Ambient temperature range:	T _{amb} -20 °C ... +60 °C	-20 °C ... +50 °C
Intrinsically safe data and supply circuit (terminals X5...X10):		
maximum voltage	U _m 253 V AC	253 V AC
maximum output voltage	U _o 5.5 V DC	5.5 V DC
maximum output current	I _o 440 mA	769 mA
maximum output power	P _o 1.25 W	2.17 W
minimum internal resistance	R _i 25 Ω	14.7 Ω
characteristic	trapezoid	trapezoid
maximum external capacitance	C _o < 997 μF (L _o = 0)	< 997 μF (L _o = 0)
max. external inductance	L _o < 0.4 mH (C _o = 0)	< 0.11 mH (C _o = 0)
max. internal inductance	L _i negligible	negligible
max. internal capacitance	C _i < 2.2 μF	< 2.2 μF

Non-intrinsically safe data and supply circuit (terminals X1...X4):		
Supply circuit	12 V DC ±10 % 230 mA (xxxx.1x)	12 V DC ±10 % 360 mA (xxxx.2x)
RS232-output (Tx/D)	(Tx/D) ±12 V, 4 mA	±12 V, 4 mA
Equipotential bonding (shielding)	(PA) terminal PA	terminal PA



IECEx Certificate of Conformity - Annex



Certificate No: IECEx IBE 19.0023X

Issue No: 0

Date of Issue: 2019-09-11

Page 3 of 4

Supply cable USB

Type

iSCANPSCABU

iSCANPSCABUX

Type of protection:

Ex mc [ic] IIC/IIB T4
Ex mc [ic] IIIC T135°C

Ambient temperature range: T_{amb} -20 °C ... +70 °C

Intrinsically safe supply circuit (terminals X8...X10):

maximum voltage	U_m	253 V AC
maximum output voltage	U_o	6.38 V DC
maximum output current	I_o	1.071 A
maximum output power	P_o	6.83 W
characteristic		rectangular

Intrinsically safe data circuit (terminals X6, X7):

maximum voltage	U_m	253 V AC
maximum output voltage	U_o	4.82 V DC
max. output current / sum	I_o	39.2 mA
maximum output current / D+	I_o	19.6 mA
maximum output current / D-	I_o	19.6 mA
maximum output power	P_o	47.1 mW

intrinsically safe circuit (in total) (terminals X6 ... X10):

maximum voltage	U_m	253 V AC
maximum output voltage	U_o	6.38 V DC
max. output current / sum	I_o	1.11 A
maximum output power	P_o	6.88 W
max. internal capacitance	C_i	< 4.53 μ F
max. internal inductance	L_i	negligible
maximum external capacitance	C_o	< 265 μ F ($L_o = 0$) (for IIC) < 1500 μ F ($L_o = 0$) (for IIB)
max. external inductance	L_o	< 0.06 mH ($C_o = 0$) (for IIC and IIB)

Non-intrinsically safe data and supply circuit (terminals X1 ... X5):

Supply circuit	5 V DC \pm 10 % (USB2.0)
USB-circuit	\pm 5 V, D+: 68 mA (X1), D-: 68 mA (X2)
Equipotential bonding (shielding)	terminal X3



IECEx Certificate of Conformity - Annex



Certificate No: IECEx IBE 19.0023X

Issue No: 0

Date of Issue: 2019-09-11

Page 4 of 4

Serial supply cable

iSCANPSCABR

Type

iSCANPSCABRX

Type of protection:

Ex mc [ic] IIC/IIB T4
Ex mc [ic] IIIC T135°C

Ambient temperature range: T_{amb} -20 °C ... +70 °C

Intrinsically safe supply circuit (terminals X8...X10):

maximum voltage	U_m	253 V AC
maximum output voltage	U_o	6.38 V DC
max. output current	I_o	1.071 A
maximum output power	P_o	6.83 W
characteristic		rectangular

Intrinsically safe data circuit (terminals X10, X11):

maximum voltage	U_m	253 V AC
-----------------	-------	----------

intrinsically safe circuit (in total) (terminals X8 ... X11):

maximum voltage	U_m	253 V AC
maximum output voltage	U_o	6.38 V DC
max. output current / sum	I_o	1.071 A
maximum output power	P_o	6.83 W
max. internal capacitance	C_i	126.2 nF
max. internal inductance	L_i	negligible
maximum external capacitance	C_o	< 280 μ F ($L_o = 0$) (for IIC) < 1500 μ F ($L_o = 0$) (for IIB)
max. external inductance	L_o	< 0.068 mH ($C_o = 0$) (for IIC and IIB)

Non-intrinsically safe data and supply circuit (terminals X1 ... X7):

Supply circuit 8 ... 30 V DC (terminals X5, X7)

Data circuits RS232 Tx/D: ± 12 V, 4 mA (X1)

RS422: +12 V / -7 V T+: 4 mA (X3), T-: 4 mA (X4)

Equipotential bonding
(shielding)

terminal X6